

ANCHOR BOLT SETTING SCHEDULE

EQUIPMENT DESIGNATION	QUANTITY	ANCHORS PER LOCATION	DESCRIPTION	TOTAL ANCHORS	ANCHOR PROJECTION	EQUIPMENT
6	2	4	3/8"Ø HILTI HY-200 EPOXY ADHESIVE ANCHOR, 6" OF EMBEDMENT	8	1-1/2"	MOKON OPEN CIRCUIT SINGLE ZONE DURATHERM
7	1	20	3/8"Ø HILTI HY-200 EPOXY ADHESIVE ANCHOR, 6" OF EMBEDMENT	20	1-1/2"	MOKON AIR COOLED OUTDOOR CHILLER
12	2	-	N/A	-	-	EXPANSION TANK
14	4	1	1/2"Ø HILTI HY-200 EPOXY ADHESIVE ANCHOR, 6" OF EMBEDMENT	4	1-1/2"	PIPE SUPPORT, SINGLE POINT
15	3	4	1/2"Ø HILTI HY-200 EPOXY ADHESIVE ANCHOR, 6" OF EMBEDMENT	12	1-1/2"	PIPE SUPPORT, FLANGED BASE
16	1	3	7/16"Ø HILTI HY-200 EPOXY ADHESIVE ANCHOR, 6" OF EMBEDMENT	3	1-1/2"	SHELCO FILTER

NOTES:

- CONTRACTOR SHALL USE EQUIPMENT AS A TEMPLATE TO LOCATE ANCHORS IN CONCRETE.
- CONTRACTOR TO CONFIRM EQUIPMENT FOOTPRINT, CONDUIT, AND GROUND PENETRATION PRIOR TO POURING PAD.
- SEE CHILLER & HEATER PAD CONDUIT PLAN, DWG. MAN17077-D-1308 FOR CONDUIT PLACEMENT DETAILS.
- GLYCOL CONNECTIONS TO BE DESIGNED AND INSTALLED BY OPTIMIZATION. FOR PIPING DETAILS SEE OPTIMIZATION DRAWING SET BEGINNING WITH PA001.

REFERENCE DRAWINGS:

- MAN17077-D-0001 BATTERY STORAGE LOCATION PLAN
- MAN17077-D-1103 FOUNDATION DETAILS

CLC Engineering
A LIMITED LIABILITY CORPORATION
1000 SULLY DRIVE • ALDORFERIA, LA 71103
WWW.CLCENGINEERING.COM

VIONX ENERGY

RC-USEMMSTO
The document contains information confidential to Siemens Energy, Inc. It is submitted in confidence and is to be used solely for the purpose for which it is furnished and returned on request. This document and each information is not to be reproduced, transmitted, disclosed or used otherwise, in whole or in part, without the written consent of Siemens Energy, Inc. 5000 SULLY DRIVE, ALDORFERIA, LA 71103


SIEMENS

© 2017 EPS ENGINEERING & DESIGN INC.
DRAWINGS AND SPECIFICATIONS ARE NOT INTENDED FOR USE ON OTHER PROJECTS AT THIS SITE OR OTHER SITES WITHOUT WRITTEN APPROVAL OF THE ENGINEER.

VIONX ENERGY - 905-0522
BATTERY STORAGE SYSTEM
SHIRLEY, MA

EPS ENGINEERING & DESIGN
A Division of Electric Power Systems International, Inc.
1338 E. KINGSLEY, SUITE 8
SPRINGFIELD, MO 65804
PHONE: (417) 886-4840
FAX: (417) 886-4842

DRAFTER: MAG	ENGR: BDP	DATE: 14 JUL 17
CHECKER: BDP	APPD: DRP	SCALE: 3/8" = 1'-0"
REV	DATE	DESCRIPTION
0	22 DEC 17	ISSUED FOR CONSTRUCTION



CHILLER EQUIPMENT FOUNDATION PLAN

DRAWING NO. MAN17077-D-1102
REV. 0