

LOCATION MAP
NTS


NOTES:

- WORKSPACE BOUNDARIES PER 2017 NEC TABLES 110.26(A)(1) & 110.34(A).
- 3'-6" IS ACHIEVED FROM ENERGIZED CONDUCTOR TO THE OPPOSITE GROUNDED DEVICE AND NOT FROM OUTER SURFACE TO OUTER SURFACE.

REFERENCE DRAWINGS:

- MAN17077-D-1201 GROUNDING PLAN
- MAN17077-D-2001 ELECTRICAL EQUIPMENT PAD PLAN VIEW

DRAWING NOT ISSUED FOR CONSTRUCTION. FINAL QA/QC TO BE PERFORMED PRIOR TO APPLYING SEAL.



RC-USEMMSTO
The document contains information confidential to Siemens Energy, Inc. It is submitted in confidence and is to be used only for the purpose for which it is furnished and returned on request. This document and each information made be reproduced, transmitted, disclosed or used otherwise, in whole or in part, without the written authorization from Siemens Energy, Inc.

SIEMENS

© 2017 EPS ENGINEERING & DESIGN INC.
DRAWINGS AND SPECIFICATIONS ARE NOT INTENDED FOR USE ON OTHER PROJECTS AT THIS SITE OR OTHER SITES WITHOUT WRITTEN APPROVAL OF THE ENGINEER.

VIONX ENERGY 905-0522 BATTERY STORAGE SYSTEM SHIRLEY, MA			
DRAFTER: JBH	ENGR: SDE	DATE: 16 JUN 17	
CHECKER: MB	APPD: PLK	SCALE: 3/8"=1'-0"	
REV	DATE	DESCRIPTION	
0	24 DEC 17	ISSUED FOR CONSTRUCTION	
1	12 JAN 18	CORRECTED BOUNDARIES	
2	15 OCT 18	CORRECTED BOUNDARIES	
WORKSPACE BOUNDARIES		DRAWING NO.	REV.
		MAN17077-D-2000	2